



NOTES:

- 1) INSTALL MANHOLE COVER ON DOWNSTREAM SIDE OF MANHOLE. TWENTY FOUR INCH (24") MANHOLE FRAME AND COVER TO BE SUPPLIED BY DISTRICT.
- 2) CONTRACTOR MAY INSTALL A 3" MAX, NON SHRINK GROUT LEVELING COURSE; UNDER FRAME TO MATCH PAVEMENT GRADE.
- 3) ALL JOINTS SHALL BE GROUTED INSIDE AND OUT; CONTRACTOR SHALL INSTALL JOINT SEALING COMPOUND AT ALL JOINTS AND UNDER FRAME COMPOUND SHALL BE: "RAM-NEK" BY K.T. SNYDER COMPANY; OR APPROVED EQUAL
- 4) FOR SHALLOW MANHOLES, THE CONTRACTOR SHALL SUBSTITUTE A PRE CAST CONCRETE MANHOLE CAP, DESIGNED FOR H-20 TRAFFIC LOADING, IN LIEU OF THE ECCENTRIC CONE. THE TWENTY FOUR INCH (24") OPENING SHALL BE LOCATED IN THE CENTER OF THE MANHOLE CAP. PROVIDE A DESIGN SUBMITTAL, PREPARED AND SEALED BY A QUALIFIED REGISTERED ENGINEER, DEMONSTRATING COMPLIANCE WITH REQUIRED LOADING CRITERIA.

A
1

MANHOLE HEAVY TRAFFIC

NO SCALE

FILE: STANDARDS	DATE: JUL 2016
SHEET: S7-D1	SCALE: NO SCALE
	DRAWN: MAM

SEWER DETAILS



SOUTH TAHOE PUBLIC UTILITY DISTRICT

Sewer . 1950 . Water A PUBLIC AGENCY
1275 Meadow Crest Drive South Lake Tahoe, California 96150
Phone (530) 544-6474 Fax (530) 541-4319
WWW.STPUD.US