

NOTES:

- 1) ALL JOINTS AND CONNECTIONS SHALL BE WATERTIGHT.
- 2) ALL BUILDING SEWERS SHALL HAVE A MINIMUM GROUND COVER OF THREE FEET (3') OVER THE TOP OF PIPE.
- 3) ALL LATERALS SIX INCHES (6") AND LARGER SHALL BE CONNECTED TO SEWER MAIN USING A STANDARD MANHOLE.



DATE:
JUL 2016

SCALE:
NO SCALE

DRAWN:
MAM

FILE:
STANDARDS

SHEET:
S7 — D9

SEWER DETAILS



SOUTH TAHOE PUBLIC UTILITY DISTRICT

Sewer . 1950 . Water A PUBLIC ACENCY 1275 Meadow Crest Drive South Lake Tahoe, California 96150 Phone (530) 544–6474 Fax (530) 541–4319 WWW.STPUD.US